



Mr. Pieter Brouwer
Rinos bv
Klaas Fuitestraat 12
NL-8281 BZ GENEMUIDEN
NEDERLAND

Your message - reference

-

our reference

PW/3430

Gent

2025-09-22

Certification report 25/3430

1. Description of the flooring:

Product family	Tufted entrance matting 100 % Polyamide PVC backing
Total mass	2500 g/m ² - 4200 g/m ²
Effective pile thickness	4.5 mm – 8.0 mm

2. Test results:

Classification according to EN 13501-1:2007+A1 (2009)

Class	EN ISO 11925-2 or CWFT (EN 14041 - 2004)	EN ISO 9239-1 (30 min.)
C _{fl}	E _{fl}	heat flux \geq 4.5 kW/m ²

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

CENTEXBEL • textile competence centre • www.centexbel.be

GENT • Technologiepark 70 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be

VAT • BE 0459.218.289 • **IBAN •** BE 44 2100 4729 6545 • **BIC •** GEBABEBB



addressee

Rinos bv

our reference

PW/3430

Gent

2025-09-22

page

2

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

loose-laid tested on a non-combustible substrate¹

Cfl - s1

Related commercial names to this product group	Hudson Nelson Matador Sonata Collect Nubia Prisma Fern Gobi Dimensions Gibson Colorado Pine Connection	Luxor Aqua 85 Panthera Delta Symphony Symphony2 Pebble Victoria Moss Volante Sahara Wave Sahara Grafic (Print) Stelvio
The obtained classification is based on the next test reports	Centexbel: 23.02008.01 dd 2023-04-28 Centexbel: 25.03075.01 dd 2025-07-22 Centexbel: 25.03075.02 dd 2025-07-22	
Validity of the certificate	2028-04-28	

Petra Wittevrongel
Product Certifier

¹ End use substrates of classes A1 or A2-s1,d0 (ISO 13238:2010 § 5.2.2)